

1:1 patch Yes/No		GARRICK THEATRE LIGHTING DESK PATCH SHEET									
		DATE ...../...../..... Square One Lighting Rig									
Desk Channel	Dimmer Channel	Stage Socket	Colour	Area/ Function	Load KW	Desk Channel	Dimmer Channel	Stage Socket	Colour	Area/ Function	Load KW
1	1		L103 Straw	DSR	.65	25	25		L020 Med Amb	USR B/L	.65
2	2		L103 Straw	DSC	.65	26	26		L020 Med Amb	USC B/L	.65
3	3		L103 Straw	DSL	.65	27	27		L020 Med Amb	USL B/L	.65
4	4		L117 Steel B	DSR	.65	28	28		L036 Med Pnk	DSR SPOT	.65
5	5		L117 Steel B	DSC	.65	29	29		L036 Med Pnk	DSC SPOT	.65
6	6		L117 Steel B	DSL	.65	30	30		L036 Med Pnk	DS SPOT	.65
7	7		L103 Straw	MSR	.65	31	31		L103 Straw	Door Special	.65
8	8		L103 Straw	MSC	.65	32	32		L103 Straw	Door Special	.65
9	9		L103 Straw	MSL	.65	33	33		L103 Straw	Window Special	.65
10	10		L117 Steel B	MSR	.65	34	34		L106 Red	CYC 1-3 x acclaim	1.5
11	11		L117 Steel B	MSC	.65	35	35		L079 Just Blue	CYC 2-3 x acclaim	1.5
12	12		L117 Steel B	MSL	.65	36	36		L101 Yellow	CYC 3- x acclaim	1.5
13	13		L103 Straw	USR	1.3	37	37				
14	14		L103 Straw	USC	1.3	38	38				
15	15		L103 Straw	USL	1.3	39	39				
16	16		L117 Steel B	USR	1.3	40	40				
17	17		L117 Steel B	USC	1.3	41	41				
18	18		L117 Steel B	USL	1.3	42	42				
19	19		L020 Med Amb	DSR B/L	.65	43	43				
20	20		L020 Med Amb	DSC B/L	.65	44	44				
21	21		L020 Med Amb	DSL B/L	.65	45	45				
22	22		L020 Med Amb	MSR B/L	.65	46	46				
23	23		L020 Med Amb	MSC B/L	.65	47	47				
24	24		L020 Med Amb	MSL B/L	.65	48	48				

Dimmers are normally Ch 1-4 phase A Ch 5-8 phase B Ch 9-12 phase C

Phase A Ch 1-4, 13-16, 25-28, 37-40 Phase B Ch 5-8, 17-20, 29-32,41- 44 Phase C Ch 9-12, 21-24, 33-36,45- 48

Total Loading phase Dimmer 1 2.6kW per phase 11A. Dimmer 2 A 5.2kW 21A B 3.9kW 16A C 2.6kW 11A

Dimmer 3 A 2.6kW 11A B 2.6kW 11A C 5.15kW 21.5A

Don Allen Electronics